

E7/... SERIES

SOLENOID VALVES FOR LIGHT OIL, OPERATING PRESSURE UP TO 20 bar.



GENERAL DESCRIPTION

This series solenoid valves are of normally closed type, quick operating, suitable for civil and industrial applications, supplied with alternate or direct current and can be fitted with a wide range of connections which make the assemblage easier and permit to avoid the utilisation of junctions, often onerous and quite unpractical.

Versions marked with "U" in their body type reference, even "TS-S" version, are UL approved.

TECHNICAL FEATURES

Supply voltage (1): Supply voltage for UL approved	230 V / 50 Hz d versions: 220 V / 60 Hz
	120 V / 60 Hz
Operating pressure range:	$0 \div 20$ bar (orifice ø 1,5 mm)
	0 ÷ 18 bar (orifice ø 2 mm)
	0 ÷ 2 bar (orifice ø 4 mm)
Room temperature:	0 ÷ 60 °C
Maximum fuel temperature:	0° 08
Closing and opening time:	≤ 1 s
Consumption:	11 VA
Flow (2):	0.055 m³/h
Weight (2):	230 g
Mounting position:	all
Body:	die-cast brass

- (1) Versions with different supply voltage are available.
- (2) These values are indicative, as with the changing of utilised body type, removals from indicated values can occur.

OVERALL DIMENSIONS





AVAILABLE BODY TYPES



INSTALLATION

- Respect the applicable national and European standards (e.g. EN 60335-1) regarding electrical safety.
- Even in the versions without earth conductor the installation must ensure the valve body connection to earth to guarantee
 adequate protection against the risk of electric shock (EN 60335-1).
- Assemble the valve to the installation so that the arrow on the valve body has the same direction as the fuel flow.
- During the assembly of the valve to the installation piping, do not twist on the sheath but on the valve body.
- Make sure that no foreign matters have entered the valve body.
- Always fit a filter to the valve inlet with a mesh section not exceeding 0.5 mm.
- Ensure a perfect connection between the valve earth conductor and the earth of the installation.
- Make sure that the max. fuel input pressure never exceeds the value appearing on the label.

CHECKING AT START

Check the valve before the first start, after any overhaul or a long period of non-operation of the system. In particular, check the valve seal where the supply piping is connected to the valve; check the valve opening and closing according to the electrical signal received by the solenoid.

DIRECTIONS FOR THE REPLACEMENT OF THE SOLENOID

To replace the solenoid, proceed as follows:

- switch off the main switch providing supply voltage to the system;
- remove the stop ring;
- remove the solenoid from the valve sheath;
- insert the new solenoid and proceed in the opposite way to assemble the valve.







T-U

1/8" NPT M

NOTES FOR PRODUCT DISPOSAL

The device contains electronic components and cannot therefore be disposed of as normal household waste. For the disposal procedure, please refer to the local rules in force for special waste.

1.5 mm

1.5 mm

7/16-20 M

ATTENTION --> Company Brahma S.p.A. declines any responsibility for any damage resulting from Customer tampering with the device.

BRAHMA S.p.A. Via del Pontiere, 31 37045 Legnago (VR) - ITALY Tel. +39 0442 635211 - Fax +39 0442 25683 http://www.brahma.it

04/11/2022 Subject to amendments without notice

Winding type

Type

А

Description

Supply in alternate current